

51182. (a) A person who owns, leases, controls, operates, or maintains any occupied dwelling or occupied structure in, upon, or adjoining any mountainous area, forest-covered land, brush-covered land, grass-covered land, or any land that is covered with flammable material, which area or land is within a very high fire hazard severity zone designated by the local agency pursuant to Section 51179, shall at all times do all of the following:

(1) Maintain around and adjacent to the occupied dwelling or occupied structure a firebreak made by removing and clearing away, for a distance of not less than 30 feet on each side thereof or to the property line, whichever is nearer, all flammable vegetation or other combustible growth. This paragraph does not apply to single specimens of trees or other vegetation that is well-pruned and maintained so as to effectively manage fuels and not form a means of rapidly transmitting fire from other nearby vegetation to any dwelling or structure.

(2) Maintain around and adjacent to the occupied dwelling or occupied structure additional fire protection or firebreaks made by removing all brush, flammable vegetation, or combustible growth that is located within 100 feet from the occupied dwelling or occupied structure or to the property line, or at a greater distance if required by state law, or local ordinance, rule, or regulation. This section does not prevent an insurance company that insures an occupied dwelling or occupied structure from requiring the owner of the dwelling or structure to maintain a firebreak of more than 100 feet around the dwelling or structure if a hazardous condition warrants such a firebreak of a greater distance. Grass and other vegetation located more than 30 feet from the dwelling or structure and less than 18 inches in height above the ground may be maintained where necessary to stabilize the soil and prevent erosion. This paragraph does not apply to single specimens of trees or other vegetation that is well-pruned and maintained so as to effectively manage fuels and not form a means of rapidly transmitting fire from other nearby vegetation to a dwelling or structure.

(3) Remove that portion of any tree that extends within 10 feet of the outlet of any chimney or stovepipe.

(4) Maintain any tree adjacent to or overhanging any building free of dead or dying wood.

(5) Maintain the roof of any structure free of leaves, needles, or other dead vegetative growth.

(6) Prior to constructing a new dwelling or structure that will be occupied or rebuilding an occupied dwelling or occupied structure damaged by a fire in that zone, the construction or rebuilding of which requires a building permit, the owner shall obtain a certification from the local building official that the dwelling or structure, as proposed to be built, complies with all applicable state and local building standards, including those described in subdivision (b) of Section 51189, and shall provide a copy of the certification, upon request, to the insurer providing coverage of construction insurance coverage for the building or structure. Upon completion of the construction or rebuilding, the owner shall obtain from the local building official, a copy of the final inspection report that demonstrates that the dwelling or structure was constructed in compliance with all applicable state and local building standards, including those described in subdivision (b) of Section 51189, and shall provide a copy of the report, upon request, to the property insurance carrier that insures the dwelling or

structure.

(b) A person is not required under this section to maintain any clearing on any land if that person does not have the legal right to maintain the clearing, nor is any person required to enter upon or to damage property that is owned by any other person without the consent of the owner of the property.